Bottom panels would be tinted/ painted 1/2" plexiglass or other thin material to give a reveal appearance.

Horizontal hollow

metal mullion, to
match height of

adjacent window

sill.

Do away with this sliver of glass, and

- center the doors in
- the opening.
- ιιι

 \mathbf{x}

Bottom rail of doors will be 12". These doors currently do not meet ADA standards (for 10" uninterrupted surface).

Both of these jambs would be the same width, to give a more uniform appearance.